

# VLR 70 L Trend EU

DECENTRALISED

PRODUCT-NO.: 203133

## Experience a strong performance in an inconspicuous design

This decentralised ventilation unit supplies fresh air to up to 60 m<sup>2</sup> of living space. Virtually no heat is lost, as it is fed back into the room with the outdoor air supply. This can help to reduce heating energy losses by as much as 89 %.

## Keep pollutants out

Dirt and pollen don't stand a chance of finding their way into your home through this ventilation unit. Particularly good filter performance is achieved by filters on both the inside and outside of the unit. As a result, people with allergies can breathe a sigh of relief as well.



## The main features

Decentralised ventilation unit for rooms with external walls

---

Very easy to clean thanks to the aluminium surface of the heat exchanger

---

Can provide intensive ventilation with low noise emissions

---

High air quality, plus long service life through the use of two filters per fan

---

Fitted with a fine dust/pollen filter making it ideal for allergy sufferers

---

Moisture recovery of up to 60 %

---

Control up to 8 units with the user interface

---

Recovery of up to 89 % of the thermal energy in the extract air



Type	VLR 70 L Trend EU
Part no.	203133

### Technical data

Air flow rate	20/30/40/49/70 m <sup>3</sup> /h
IP rating	IP21
Rated voltage	24 V
Sound power level LW total relative to air flow rate	36 (20 m <sup>3</sup> /h) dB(A)
Weight	5.20 kg
Min. outlet aperture	Ø 200, 185x185 mm
Height	285 mm
Width	360 mm
Depth	780 mm
Energy efficiency class, moderate climates, central demand-dependent control	A+

## **Contact information**

Do you have additional questions? Then please do not hesitate to contact us, we would be only too happy to help:

Call 0151 346 2300

Or send an e-mail to

[sales@stiebel-eltron.co.uk](mailto:sales@stiebel-eltron.co.uk)

Only a qualified contractor should carry out the installation, commissioning, maintenance and repair of this appliance. Where applicable and prior to installation the electricity and/or water utility companies should be notified of your intention to install the product.